

**INVITATION TO BID
ADDENDUM #2 (FINAL) – Commercial Structures and Facilities Painting**

THE CITY OF MURFREESBORO

MURFREESBORO WATER AND SEWER DEPARTMENT

ITB SUBMITTAL DEADLINE DATE: January 20, 2015

ITB SUBMITTAL DEADLINE TIME: 2:00 p.m. Murfreesboro, Tennessee, local time

1. Question #4.

Question: Should pipe stenciling and plastic decal marking be included for pipe that is to be painted?

Response: Yes.

2. Question #5.

Question: Will pipe be taken out of service and empty during the painting process?

Response: In most cases no. Only if it will not affect plant operations. Must be coordinated with Plant Manager.

3. Question #6.

Question: Should the catwalk steel and grating be painted around the top of the Lime Silo's?

Response: No.

Date of Addendum: Tuesday, January 13, 2015